

CERTIFICATE

Permission to use the test mark

***VOLUNTARY PRODUCT TEST
BASED ON VDI 6022-1:2018
– Tested Hygiene Characteristics –***

TÜV NORD Systems GmbH & Co. KG, Hamburg (Germany),

hereby confirms that the Air Humidifying System

“HPS”

is conform to the requirements set by VDI 6022-1 and VDI 3803-1.

HygroMatik GmbH, Henstedt-Ulzburg (Deutschland),

is therefore granted the right to use the test mark shown below
in connection with the above-mentioned product.

TÜV NORD Systems GmbH & Co. KG
Test Laboratory for Ventilation, Air Conditioning, Refrigeration



Dipl.-Ing. Monika Steimle

Essen, 21 March 2022

The certification is based upon a type examination of an Air Humidifying System and not of a complete system installed in a building.
The validity of the certificate is 15 months.
All regulations concerning test mark use are laid down in the corresponding agreement.

